

## Memorandum

**Date:** January 17, 2024  
**To:** Billi Jo Huddleston, CHMM, Florida Power & Light Company  
**From:** Ben Amos, Ph.D., P.E. and Lane Dorman, P.G., Geosyntec Consultants, Inc.  
**Subject:** 2020 Groundwater Velocity Estimate, Gulf Clean Energy Center,  
Gypsum Storage Area, Pensacola, FL

---

### INTRODUCTION

On behalf of Florida Power & Light Company (“FPL”), Geosyntec Consultants, Inc. (“Geosyntec”) prepared this *2020 Groundwater Velocity Estimate Memorandum* (“Memo”) for FPL’s Gulf Clean Energy Center (“GCEC”) Coal Combustion Residuals (“CCR”) unit Gypsum Storage Area (“GSA”). The purpose of this Memo is to document the calculated horizontal groundwater velocities at the GSA in 2020. This Memo supplements the summary of CCR groundwater monitoring activities conducted in 2020 and reported in the *2020 Annual Groundwater Monitoring and Corrective Action Report* (Geosyntec, 2021<sup>1</sup>), in accordance with groundwater sampling and analysis requirements of 40 Code of Federal Regulations (“CFR”) Section 257.93(c).

### GROUNDWATER VELOCITY CALCULATIONS

Groundwater flow rates were calculated based on the following:

1. Horizontal hydraulic gradients estimated from groundwater elevations measured during each sampling event in 2020.
2. The geometric mean (geomean) hydraulic conductivity (64 feet per day [ft/day]) for the GSA documented in the *APT Well Installation, Development, and Testing Report, Crist Generating Plant* (Geosyntec, 2017<sup>2</sup>).

---

<sup>1</sup> Geosyntec Consultants, 2021. *2020 Annual Groundwater Monitoring and Corrective Action Report*, Gulf Power Company, Plant Crist, Gypsum Storage Area. January 29, 2021.

<sup>2</sup> Geosyntec Consultants, 2017. *APT Well Installation, Development, and Testing Report, Crist Generating Plant*. November.

3. An estimated effective porosity of 0.25, based on the lithologic materials surrounding the screened interval (Sterrett, 2007<sup>3</sup>).

Input parameters and calculations are summarized in **Table 1**. Groundwater elevation maps from 2020 are included as **Figures 1 and 2**.

Horizontal hydraulic gradients between MW-204 and MW-206, a monitoring well-pair representative of groundwater flow near GSA, were calculated based on groundwater elevation data from both 2020 groundwater sampling events. The resulting horizontal gradients were approximately 0.0018 ft/ft and 0.0017 ft/ft in April and October 2020, respectively.

The geomean hydraulic conductivity for the uppermost aquifer adjacent to the GSA was estimated from aquifer testing data from seven extraction wells around the GSA (Geosyntec, 2017). The lithology of this aquifer generally consists of fine to coarse sand (SCS, 2017<sup>4</sup>); the geomean hydraulic conductivity (64 ft/day) is within the anticipated hydraulic conductivity range for a fine to coarse sand (Freeze and Cherry, 1979<sup>5</sup>).

The horizontal groundwater flow velocity was calculated using a form of Darcy's Law:

$$V = (K*i)/n_e$$

Where:

V = groundwater velocity (ft/day);

K = hydraulic conductivity (ft/day);

i = horizontal hydraulic gradient (ft/ft); and

$n_e$  = effective porosity (unitless).

The calculated horizontal groundwater flow velocities at the GSA were 0.46 ft/day (168 ft/year) in April 2020 and 0.45 ft/day (163 ft/year) in October 2020.

## CLOSING

In accordance with the groundwater sampling and analysis requirements of 40 CFR Section 257.93(c), the horizontal groundwater velocities calculated for the selected well pair at GSA (i.e., MW-204 and MW-206) were approximately 0.46 ft/day (168 ft/year) in April 2020 and 0.45 ft/day (163 ft/year) in

---

<sup>3</sup> Sterret, R.J., 2007. *Groundwater and Wells*, Third Edition, New Brighton, MN: Johnson Screens, A Weatherford Company.

<sup>4</sup> Southern Company Services, 2017. *Gulf Power Company, Plant Crist, Ash Landfill No. 1, Ash Landfill No. 2, and Gypsum Storage Area Well Design, Installation, Development and Decommissioning Report*, October.

<sup>5</sup> Freeze, R.A. and J.A. Cherry, 1979. *Groundwater*, Englewood Cliffs, NJ: Prentice Hall.

October 2020. The calculated horizontal groundwater velocities for 2020 are similar to those calculated previously (Geosyntec, 2023<sup>6</sup>). This Memo has been prepared under the supervision of a State of Florida licensed Professional Engineer and Professional Geologist with Geosyntec.

---


<sup>6</sup> Geosyntec Consultants, Inc., 2023. *2022 Annual Groundwater Monitoring and Corrective Action Report*, Florida Power & Light Company, Gulf Clean Energy Center Gypsum Storage Area, January 31, 2023  
FR8309/PR23038

---

Benjamin K. Amos, Ph.D., P.E.  
Florida Professional Engineer No. 82837


---

Date



---

Lane Dorman, P.G.  
Florida Professional Geologist No. PG2861



---

Date

# TABLE


**Table 1. 2020 Groundwater Velocity Input Parameters and Calculations  
Gulf Clean Energy Center, Gypsum Storage Area  
Pensacola, FL**

Flow Paths	Groundwater Elevation (ft) <sup>1,2</sup>		Change in Groundwater Elevation ( $\Delta h$ ) <sup>3</sup> (ft)	Distance ( $\Delta l$ ) <sup>3</sup> (ft)	Hydraulic Gradient ( $\Delta h/\Delta l$ ) <sup>3</sup> (ft/ft) <sup>4</sup>	Hydraulic Conductivity <sup>5</sup> , K (ft/day) <sup>6</sup>	Effective Porosity ( $n_e$ )	Linear Groundwater Velocity <sup>7</sup>	
								ft/day	ft/year <sup>8</sup>
MW-204/ MW-206	Apr-20	5.9	3.03	1687	0.0018	64	0.25	0.46	167.8
		2.87							
MW-204/ MW-206	Oct-20	7.64	2.95		0.0017			0.45	163.4
		4.69							

Notes:

1. Elevations are in feet relative to the North American Vertical Datum of 1988.
2. ft = feet
3.  $\Delta h$  = Change in groundwater elevation,  $\Delta l$ = Distance along flow path
4. ft/ft = feet per foot
5. K is the geometric mean of 2017 aquifer testing results from seven extraction wells around the gypsum storage area.
6. ft/day = feet per day
7. Groundwater flow velocity equation =  $(\Delta h/\Delta l * K)/n_e$
8. ft/year = feet per year

# **FIGURES**



**Legend**

- Ash Landfill No. 1 CCR Downgradient Monitoring Well Location
- Ash Landfill No. 2 CCR Downgradient Monitoring Well Location
- Ash Landfill No. 2 Piezometer Location
- Downgradient GSA CCR Monitoring Well Location
- Background CCR Monitoring Well Location
- Upgradient GSA CCR Monitoring Well Location
- Shallow Delineation Piezometer and Well Location
- Deep Delineation Piezometer and Well Location
- Groundwater Elevation Contour (ft NAVD88, dashed where inferred)
- Approximate Gypsum Storage Area Boundary
- Approximate Property Boundary
- Groundwater Elevation (ft NAVD88)

**Notes:**


1. CCR indicates Coal Combustion Residuals.
2. ft NAVD88 indicates an elevation in feet relative to the North American Vertical Datum of 1988.
3. \* indicates that contours represent groundwater and not the gypsum process water contained within the Gypsum Storage Area (GSA) lined impoundments.
4. \*\* indicates groundwater elevations at monitoring wells PZ-200D, PZ-201D, PZ-203D, and MW2032 were not used for potentiometric surface interpretation.
5. Source of property and Gypsum Storage Area boundaries: Gulf Power drawing number ES404151.
6. Source of 2019 World Imagery: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community.

800 400 0 800 Feet

**Potentiometric Surface Contour Map**  
**13 April 2020**  
**Gypsum Storage Area**  
 Crist Generating Plant  
 11999 Pate St  
 Pensacola, FL

	<b>Figure</b>  <b>1</b>
Pensacola, FL	January 2021





**Legend**

- Ash Landfill No. 1 CCR Downgradient Monitoring Well Location
- Ash Landfill No. 2 CCR Downgradient Monitoring Well Location
- Ash Landfill No. 2 Piezometer Location
- Downgradient GSA CCR Monitoring Well Location
- Background CCR Monitoring Well Location
- Upgradient GSA CCR Monitoring Well Location
- Shallow Delineation Piezometer and Well Location
- Deep Delineation Piezometer and Well Location
- Groundwater Elevation Contour (ft NAVD88, dashed where inferred)
- Approximate Gypsum Storage Area Boundary
- Approximate Property Boundary
- [13.48] Groundwater Elevation (ft NAVD88)

**Notes:**

1. CCR indicates Coal Combustion Residuals.
2. ft NAVD88 indicates an elevation in feet relative to the North American Vertical Datum of 1988.
3. \* indicates that contours represent groundwater and not the gypsum process water contained within the Gypsum Storage Area (GSA) lined impoundments.
4. \*\* indicates groundwater elevations at monitoring wells PZ-200D, PZ-201D, PZ-203D, and MW2032 were not used for potentiometric surface interpretation.
5. Source of property and Gypsum Storage Area boundaries: Gulf Power drawing number ES4041S1.
6. Source of 2019 World Imagery: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community.

800 400 0 800 Feet

**Potentiometric Surface Contour Map**  
**6 October 2020**  
**Gypsum Storage Area**  
 Crist Generating Plant  
 11999 Pate St  
 Pensacola, FL

 Geosyntec consultants	Figure <b>2</b>
Pensacola, FL	January 2021