## **Coal Combustion Residuals (CCR) Annual Fugitive Dust Control Report**

PLANT NAME: Gulf Clean Energy Center UNIT: Gypsum Storage Area (GSA)

**OWNER/OPERATOR OF FACILITY:** Florida Power & Light Company

**REPORTING TIMEFRAME:** October 19, 2021 to October 19, 2022

**PURPOSE:** The purpose of this report is to demonstrate compliance with the requirements for the annual CCR fugitive dust control report set forth in 40 CFR § 257.80 (c). This report describes the actions taken by Gulf Clean Energy Center to control CCR fugitive dust, a record of all citizen complaints and if any, a summary of corrective measures taken.

## DESCRIBE THE ACTIONS TAKEN TO CONTROL FUGITIVE DUST.

A water suppression truck was used to wet the roads in the immediate vicinity of the on-site CCR landfills and surface impoundment and were also used when reclaiming CCR for beneficial reuse, as needed. When CCR was transported off-site, enclosed tankers and/or covered trucks were used. Fugitive emissions at Gulf Clean Energy Center are also regulated under the facility's Title V Air Permit.

A water suppression truck was used on the roads at the site, as needed. Trucks carrying CCR were covered or enclosed. Speed limits were posted to reduce vehicle speeds on all roads.

HAS THE FACILITY RECEIVED ANY CCR FUGITIVE DUST		
CITIZEN COMPLAINTS WITHIN THE REPORTING	Yes	No
TIMEFRAME?		

## IF YES, INCLUDE A RECORD OF ALL CITIZEN COMPLAINTS

Date	Description of Complaint	Corrective Measures (If Any)