

# Equipment for Special Circumstances



## Wye/Open Delta Bank

- » Typical dimensions of equipment (low style):  
**40 inches long by 36 inches wide by 26 inches tall**
- » Typical dimensions of equipment (regular style):  
**40 inches long by 36 inches wide by 34 inches tall**
- » Typical concrete foundation dimensions for equipment:  
**60 inches by 80 inches**
- » Required easement for equipment's installation and operation: **13 feet by 10 feet**



## Underground Switch Cabinet

- » Typical dimensions of equipment:  
**67 inches long by 75 inches wide by 50 inches tall**
- » Typical concrete foundation dimensions for equipment:  
**82 inches by 90 inches**
- » Required easement for equipment's installation and operation: **20 feet by 20 feet**



## Underground Feeder Splice Box

- » Typical dimensions of equipment:  
**120 inches long by 60 inches wide by 41 inches tall**
- » Required easement for equipment's installation and operation: **7 feet by 22 feet**



## Three Phase Transformer

- » The dimensions may vary:  
**49 inches long by 64 inches wide by 47 inches tall** or  
**87 inches long by 100 inches wide by 71 inches tall**
- » Typical concrete foundation dimensions for transformer:  
**60 inches by 80 inches** or **106 inches by 106 inches**
- » Required easement for equipment's installation and operation:  
**10 feet by 10 feet** or **20 feet by 20 feet**